



INSPECTION REPORT.

Corres - DMR

1 - Copy

R. Robinson

To Dean Wood / Frank Monahan

Inspector D. Anderson

Date of Visit 3-14-80

Permit No. \_\_\_\_\_

Name of Entity Hoguenum Landfill

Permit Expires \_\_\_\_\_

City Hoguenum County Grays Harbor

New Industry \_\_\_\_\_

Person Contacted Gate operator

Type of Facility Landfill

Receiving Water Hoguenum River

Type of Treatment System None

Operation: ☒ Satisfactory

☐ Fair

☒ Unsatisfactory

☐ Does not comply with permit conditions

Describe Frank Monahan requested that I visit landfill site to take samples of runoff discharging from landfill site. Attached lab sheet shows data. My concern was the large amount of "uncontaminated" water entering the sewage line from the site while contaminated waters were ~~by~~ bypassing the collection system being collected by the roadside ditch then to the Hoguenum R. Seems that the drainage system is not working correctly.

cc





INSPECTION REPORT.

Corres - DMR

1. - Copy

To Dean Wood / Frank Monahan Inspector R. Robinson  
D. Anderson  
Date of Visit 3-14-80 Permit No. \_\_\_\_\_  
Name of Entity Hoguesum Landfill Permit Expires \_\_\_\_\_  
City Hoguesum County Grays Harbor New Industry \_\_\_\_\_  
Person Contacted Gate Operator  
Type of Facility Landfill  
Receiving Water Hoguesum River  
Type of Treatment System None

Operation: ☒ Satisfactory ☐ Fair ☒ Unsatisfactory

☐ Does not comply with permit conditions

Describe Frank Monahan requested that I visit landfill site to  
take samples of runoff discharging from landfill site. Attached  
lab sheet shows data. My concern was the large amount  
of "uncontaminated" water entering the sewage line from the  
site while contaminated waters were bypassing the collection  
system being collected by the roadside ditch then to the  
Hoguesum R. Seems that the drainage system is not working  
correctly.

cc





INSPECTION REPORT

To Dean Wood / Frank Monahan Inspector R. Robinson  
Date of Visit 3-14-80 Permit No. \_\_\_\_\_  
Name of Entity Hoguenam Landfill Permit Expires \_\_\_\_\_  
City Hoguenam County Grays Harbor New Industry \_\_\_\_\_  
Person Contacted Gate operator  
Type of Facility Landfill  
Receiving Water Hoguenam River  
Type of Treatment System None

Operation: ☒ Satisfactory ☐ Fair ☒ Unsatisfactory

☐ Does not comply with permit conditions

Describe Frank Monahan requested that I visit landfill site to  
take samples of runoff discharging from landfill site. Attached  
lab sheet shows data. My concern was the large amount  
of "uncontaminated" water entering the sewage line from the  
site while contaminated waters were bypassing the collection  
system being collected by the roadside ditch then to the  
Hoguenam R. Says that the drainage system is not working  
correctly.

cc

## DATA SUMMARY

ORIGINAL TO:  
Frank Monahan  
COPIES TO:

**SOURCE**

Hogium Landfill

DATE COLLECTED \_\_\_\_\_

3-14-80

COLLECTED BY

Darryl Anderson

## LAB FILES

NOTE: All results are in ppm (mg/l) unless otherwise specified. ND is "None Detected"

"<" is "Less Than" and ">" is "Greater Than"

SUMMARIZED BY

DATE \_\_\_\_\_

3-28-80

REVIEWED BY

DATE \_\_\_\_\_

3-28-80